

**By U.P.C.**

Administration of  
Dadra and Nagar Haveli, U.T.,  
Electricity Department,  
Silvassa.

No.DNH/ELE/DIV-II/59/10/833

Date:- 29/07/2010

### **C O R R I G E N D U M**

The Tender for Establishment of 66/11, 2x15 MVA Sub-station at village Kala in the UT of DNH was invited vide this Office Tender Notice No. 06/2010-2011/622, dtd.10/06/2010, which is extended up to 11.08.2010. The following corrigendum therein may please be read:-

#### **Item No.II**

#### **B) Item No.II (15 MVA Power Transformer)**

1. Schedule of Work of Item No.2 "*Design Manufacturing & Supply of 15 MVA, 66/11.55kV, copper wound, ONAN cooled Power Transformer with On Load Tap Changer (17 taps) with RTCC Panel as per enclosed terms & conditions, drawings & specification*" may be read as...  
***"Design Manufacturing, Supply, erection testing & commissioning of 15 MVA, 66/11.55kV, copper wound, ONAN cooled Power Transformer with On Load Tap Changer (17 taps) with RTCC Panel as per enclosed terms & conditions, drawings & specification"***
2. In the technical specification of 66/11kV, 15 MVA Power Transformer at Sr. No.11 of clause No. "**28.5, - POWER TRANSFORMER PRINCIPLE PARAMETERS**", the percentage impedance at rated MVA and normal tap has been indicated as **7%** with  $\pm 10\%$  tolerance which may be read as **9.5%** with  $\pm 10\%$  tolerance.

The other terms & condition will remain unchanged.

- Sd -  
Superintending Engineer (Power),  
Electricity Department,  
Dadra and Nagar Haveli,  
Silvassa.

To,

All suppliers as standard list available in department.

- The District Informatics Officer/PSA, National Informatics Center, Silvassa for information and publicity.
- The Chief Publicity Officer, Dadra & Nagar Haveli, Silvassa for publish in Hindi, Gujarati & English News paper for vide publicity.
- The Editor Tender Trade, 18, 2<sup>nd</sup> Floor "KADAMBAM" Opp. Govt. Press, Near Kothi Char Rasta, VADODARA-1 for publication of the Tender Notice.